

# CERTIFICATE OF COMPLIANCE AND QUALITY

## FINAL INSPECTION REPORT

Nr : 2015/08/10


---

<b>Issuer's name</b>	UAB „Refra“
<b>Issuer's address</b>	Registration address: Įmonių g.21, LT- 35101Panevėžys, Lithuania Manufacture address - S. Dariaus ir S. Girėno g.173, LT- 02011 Vilnius, Lithuania Tel. +370 615 71191 <a href="mailto:info@refra.eu">info@refra.eu</a> , <a href="http://www.refra.eu">www.refra.eu</a>

---

**Product description:**

<b>Type</b>	<b>Chilled Water Accumulation Tank</b>
<b>Model</b>	<b>007THT 186 S001</b>
<b>Serial No</b>	
<b>Order No</b>	
<b>Month of manufacturing</b>	

We hereby declare that the product is covered by the Article 3 Paragraph 3 of the 97/23/EC Directive, it has been designed and manufactured in accordance with a sound engineering practice and it has been positively tested by our inspection department. The product can be  marked.

### PRESSURE TEST DECLARATION

Max. working temperature	95°C
Max. working pressure	10 bar
Test pressure	14.3 bar
Volume	1000 L

Product has been tested. No leakage or other defects were detected on the product.

UAB „Refra“ Quality Control Manager.....  
(Name, function) (Signature or equivalent authorized by the issuer)